


# Gresham's Energy Independence Challenges and Successes



Alan Johnston, Senior Engineer, Wastewater Services Division

# Gresham's Wastewater Treatment Plant



- 114,000 service population (*Gresham, Fairview, Wood Village*)
- 20 mgd annual average capacity; 13 mgd current flowrate
- Secondary, Activated Sludge, Anaerobic Digestion, BFP, Chlorination/Dechlorination.
- Discharges to Columbia River
- WWTP and PS O&M provided under contract with Veolia Water
- 16 FTE in Operations & Maintenance (Veolia Water)
- 3 FTE in WWTP and PS Engineering (Gresham)

# Energy Discussion Items

- Gresham's Sustainability Policy (carbon footprint reduction)
- 400 kw Cogeneration
- 420 kw Peak DC Solar plant
- MicroHydro in our Outfall Pipeline
- FOG Receiving Station (under construction)
- Energy Conservation (Linear Motion Mixers, Neuros Blowers)
- WWTP Energy Consumption and Production Data
- Energy Management Plan (Keep it simple)
- Power Monitoring
- Lofty Goal: Energy Independence by FY 2015/16?

# Gresham's Sustainability Policy

Adopted by Gresham City Council in 2009.

“The City of Gresham will strive to design and deliver services that:

- Support a stable, diverse and equitable economy.
- Promote community health and well-being, outdoor recreation, cultural awareness, and encourage learning.
- Protect and improve the quality of the air, water, land and other natural resources by reducing human impacts and increasing public awareness of the valuable services the environment provides.”

# Gresham's Sustainability Policy

## Key Goals

- 1) 80% Reduction in City Greenhouse Gas Emissions by 2050
- 2) 100% Renewable Energy by 2030
- 3) Zero Waste in City Operations by 2020
- 4) Ongoing Protection of Natural Resources (including water quality and availability, and habitat)
- 5) Toxin Reduction and Eventual Elimination

This discussion involves Goals 1 and 2 at the WWTP.

# Gresham Cogeneration History

- 250 kw Waukesha cogenerator installed 1987 with digesters
- No biogas treatment over its lifetime
- Turned off 2003/04 due to sudden continued internal corrosion
- 400 kw Lean Burn Caterpillar cogenerator started 2005
- Installed in same footprint as Waukesha
- H<sub>2</sub>S/Siloxane/moisture removal system incorporated

# 400 kw CAT Cogenerator



# Cogeneration by the Numbers

- 93% Runtime since 2005 (off about 48 hours per month)
- Produces power and heats buildings with jacket water heat
- Haven't put a number to the financial benefits of the heat
- 50,000+ Operating Hours (no engine overhaul yet)
- 17,000,000+ **kwh** of power production
- 2.6 cents per kwh operation/maintenance expenses
- An oil change and spark plugs is \$3,200 bimonthly, or so
- Sample your oil starting at 1000 hrs runtime.
- 50% of WWTP Power needs
- \$1.5 million in avoided electrical costs.
- 3.5 year payback



# Cogeneration Financing

- City's first Design-Build contract
- Engine ordered during schematic design phase.
- Allowed start-up 6-8 months earlier than possible with conventional design-bid-build (resulting in >\$100k in energy production and savings)
- ODOE BETC Grant, Energy Trust Grant

<u>Certified Capital Cost</u>	\$1,128,633
less BETC Partner	\$287,801
less Energy Trust Grant	\$82,379
<i>Total Capital Cost</i>	<i>\$758,453</i>
Annual Power Savings	\$275,000
Annual O&M	\$40,000
Payback	3.5 years

# Biogas Scrubbing

- 9000 scfh Design Flow (7000 scfh at 400 kw engine output)
- H<sub>2</sub>S Scrubbing Tank (Change media as needed)
- Booster Blower (Design in redundancy)
- Heat exchanger (Chill gas to 40 F)
- Moisture Removal
- Heat Exchanger (Heat gas to 70 F)
- Siloxane Tank (Change media once per year)
- Treated Biogas to Engine or boiler




Upper Plant Influent Flow Rate	6.97 MGD
Lower Plant Influent Flow Rate	5.09 MGD
Common Effluent Flow Rate	12.06MGD

Alarms



Time: 11:13:03 AM  
 Date: 12/5/2011  
 Version: 43.420

### Anaerobic Digester Elevation





Upper Plant Influent Flow Rate	9.33 MGD
Lower Plant Influent Flow Rate	4.21 MGD
Common Effluent Flow Rate	12.52 MGD

Alarms




Time: 11:09:04 AM  
Date: 12/5/2011  
Version: 43.420

File Edit Location Upper Lower Alarms Hist Trends RT Trends Remote Status Help Back Forward A/F Trends Unack'd 900 Alarms 0

Header Off  
Header On  
Log On  
Log Off  
- Cancel -

W - 7641.1 SCFH  
d - 6662.4 SCFH  
er - 0.0 SCFH  
Gas Flow Waste - 936.1 SCFH  
Gas Storage - 21973.8 SCF

### FUEL TREATMENT



Generator Control Mode:  
3 - UTILITY LOAD

Engine Generator CGU-R01

Lower Plant Demand: 422 KW  
Utility Import: 56 KW  
Gen Output: 366 KW  
Gen Baseload SP: 369 KW  
Generator: 17646084 KWH

Raw Biogas

# Biogas Scrubbing

Siloxanes Treatment Tank 2


H<sub>2</sub>S Treatment Tank

Siloxanes Treatment Tank 1

Treated Biogas to engine

Booster Blower

Moisture removal




# Biogas Scrubber Media

- Largest Cost of the treatment system
- H<sub>2</sub>S Media replaced every 60-120 days, varies widely.
- H<sub>2</sub>S media changed when treated biogas > 100 ppm H<sub>2</sub>S
- Siloxane media Changed every year (switch tanks 6 months)
- 1 per year siloxanes testing, unreliable and expensive
- Storage required for media so it is ready to go
- Change oil (if needed) when media is replaced for ½ day outage.
- \$10,000 per H<sub>2</sub>S Media Changeout (3 per year)
- \$6,000 per Siloxane Media Changeout (1 per year)


# Biogas Scrubber Media

## H2S Media Change Frequency



# Cogen/Gas Scrubber Maintenance Cost Summary

Summary of Costs:	Total Maintenance Costs	City Labor Media Costs	Uptime Incentive	Total Costs	Cumul. Costs	Cost ¢/kwh	Cumul. Cost ¢/kwh
2005 (Start 11/05)	\$ 131.25	\$ -	\$ -	\$ 131.25	\$131.25	0.03	
2006	\$ 24,138.83	\$ -	\$0.00	\$ 24,138.83	\$24,270.08	0.77	0.68
2007	\$ 59,271.45	\$ 5,644.00	\$8,061.55	\$ 72,977.00	\$97,247.08	2.30	1.44
2008	\$ 98,542.27	\$ 7,953.00	\$10,822.81	\$ 117,318.08	\$214,565.16	4.09	2.23
2009	\$ 117,073.31	\$ 10,262.00	\$8,036.77	\$ 135,372.08	\$349,937.24	4.35	2.75
2010	\$ 52,481.72	\$ 10,262.00	\$4,566.55	\$ 67,310.27	\$417,247.51	2.13	2.62
Total:	\$ 351,638.83	\$ 34,121.00	\$ 31,487.68	\$ 417,247.51			
Average:	\$ 58,606.47	\$ 5,686.83	\$ 5,247.95	\$ 69,541.25		2.62	





# Audience Poll Question



If you have a cogen system, do you have a biogas scrubber?

# Solar Update



- 420 kW peak capacity
- 1 acre ground-mounted system
- RFP issued in April 2008
- Power Purchase Agreement signed with Tioga in Oct. 2008
- Transferred to SunEdison in July 2009
- Installation completed in Dec. 2009
- PGE net metering agreement
- No capital cost to City
- First year kwh charge 2/3 PGE
- Fixed annual escalation

# Solar Layout



# Solar Highlights

- City's first design, build, own, operate project
- Power Purchase Agreement (PPA) negotiated (yes, 60 pages)
- Essentially leasing the land (make sure you don't need it later)
- No upfront cost from ratepayers
- SunEdison owns, operates and maintains
- COG purchases energy produced for 20 years
- Solar system purchase options after year 6
- Constructed through partnership with SunEdison, REC Solar
- Incentives provided by BETC and ETO
- REC Solar designed & installed the system

# Solar Website

- System monitoring website required of PPA
- Realtime kw, Kwh, insolation, temperature
- Monthly Invoice generation
- Calculates CO2, NOX, SO2 avoided
- [www.my.sunedison.com](http://www.my.sunedison.com)
- Public login, UN: gresham.kiosk, PW: Gresham@wwtp1
- Show website!

# Solar By The Numbers

- 420 kw Peak DC Capacity
- Payback in years = 0
- Capital Cost to City = \$0
- O&M Costs to City = \$0
- COG purchases energy produced for 20 years
- 2010 Power Production 450,181 kwh
- 2011 Power Production 437,116 kwh
- Average Monthly Solar Invoice \$2,200
- Average Monthly avoided utility cost \$1,100
- Produced 8% of WWTP demand in 2011

# Audience Poll Question



Is your organization interested in solar power?

# MicroHydroPower



- Produce power from a 36 foot (annual average) gravity fall
- 60 kw Frances Turbine, 600 rpm, 480 v
- Install Powerhouse near shore of Columbia River
- Permitting has been and still is lengthy
- Water Rights permit from State (Done)
- FERC Permit (conduit exemption) for powerhouse (Done, took about 2 years)
- Flood Plain Development Permit for flood plain construction (pending)
- Levee encroachment permit with Drainage District (pending)
- Still evaluating grant options and feasibility of project
- Looking at public/private ownership options



# MicroHydroPower

Oct 15, 2008 - 7:56pm poveson



P:\135359 Gresham Sewer HydroDrawings\Hydroplant Site Plan Update.DWG



<b>BROWN AND CALDWELL</b>  PLAN	<b>GRESHAM SEWER HYDRO</b> FIGURE 3. PRELIMINARY SITE PLAN		ARCHIVE DETAIL NUMBER	BC STANDARD DETAIL NUMBER
			DATE REVISED: 09-2008	APPROVED BY:

# MicroHydroPower

ACAD-600-187-112004 CFM OMH  
01/04/2012  
TAB



REVISION	DATE	DESCRIPTION	DRAWN BY	APP'D BY	PRDL. MOD.	DRAWN BY	DATE	CLIENT	REVISION
						TAB	01/04/2012	CITY OF GRESHAM	0
						CFM	01/04/2012	PROJECT	GH CV-5
								TITLE	1 of 1



**C F MALM ENGINEERS LLC**  
5511 SIXTH AVENUE SOUTH  
SEATTLE, WASHINGTON 98108  
206-270-0460  
cfm@cfmalm.com

DRAWN BY	DATE	CLIENT
TAB	01/04/2012	CITY OF GRESHAM
CHK'D BY	DATE	PROJECT
CFM	01/04/2012	OUTFALL MINIHYDRO
APP'VD BY	DATE	TITLE
		POWERHOUSE PLAN AND SECTION
SCALE	ISSUE	
3/16" = 1'-0"		

# MicroHydroPower Funding

- Annual power production 450,000 kwh
- Revenues from PGE Schedule 201
- Kwh purchase varies linearly from \$.04 in 2012 to \$.11 in 2032, 20 year contract.
- Annual O&M estimated at \$7,500
- Frances Turbine Cost \$385,000
- Expected Turbine Life 25 years

Estimated Capital Cost	\$905,477
less BETC Partner	\$153,000
less Energy Trust Grant	\$360,000
<hr/>	
Net Capital Cost	\$392,477

Annual Power Income	\$41,000
Annual O&M	\$7,500

Payback 12 years



# Audience Poll Question



Would you go forward with the MicroHydro project?

# Small Wind Power

- Quite windy in Gresham (near Columbia River gorge)
- Prefeasibility Study Completed (100% ETO)
- Feasibility Study Underway \$18,000 (50% ETO)
- Early Paybacks aren't promising
- Technology always changing
- Public/private partnership?
- More to Come!



## 2 Energy Efficiency Projects

- Energy Efficiency Study financed by ETO
- Replace gas mixing system (3 - 40 hp compressors)
- Install Linear Motion Mixers (LMM) for both digesters
- Each LMM has 20 hp motor and VFD
- Currently operating at 75% speed or 15 hp.
- Essentially trading 80 hp 24 hrs/day for 30 hp 24 hrs/day
- Replace 2 Hoffman multistage blowers (100 hp each)
- Install 2 Neuros Turbo blowers (100 hp each)
- Operating curves are much more efficient
- 50% variable speed turndown
- Air bearings

# 2 Energy Efficiency Projects

## 1.3 ECONOMIC SUMMARY

**Table 1: Savings and Cost Summary**

Utility Rate Schedule										
Cost of Energy:			\$0.07	/kWh						
Cost of Demand:			\$4.82	/kW/mo						
EEM No.	Description	Include in Package?	Billing Demand Savings (kW/mo)	On Peak Demand Reduction (kW/mo)	Annual Energy Savings (kWh/yr)	Annual Cost Savings			EEM Cost (\$)	Pre-Incentive Payback (Years)
						Demand Charges (\$)	Energy Charges (\$)	Total Savings (\$)		
1	Anaerobic Digester Mixing System	Yes	94	94	412,375	\$454	\$27,914	\$28,367	\$297,000	10.5
2	Upper Plant AB Mixing System	Yes	27	27	237,671	\$131	\$16,088	\$16,219	\$528,000	32.6
3	Lower Plant AB Improvements	Yes	53	53	437,983	\$256	\$29,647	\$29,903	\$319,000	10.7
4	Chiller Upgrade	No	0	0	0	\$0	\$0	\$0	\$0	0
			174	174	1,088,029	\$840	\$73,649	\$74,489	\$1,144,000	15.4

**Table 2: Incentive Summary**

Incentive Cap, % of Project Cost			50%				
Energy Incentive Rate			0.32 kWh				
EEM No.	Description	EEM Life Expectancy (Years)	Energy Trust Incentive Calculation			Cost After Incentive	Customer Final Payback (Years)
			Incentive Cap (50%)	Energy Incentive (\$)	Final Incentive (\$)		
1	Anaerobic Digester Mixing System	20	\$148,500	\$131,960	\$131,960	\$165,000	5.8
2	Upper Plant AB Mixing System	20	\$264,000	\$76,055	\$76,055	\$452,000	27.9
3	Lower Plant AB Improvements	20	\$159,500	\$140,154	\$140,154	\$179,000	6.0
4	Chiller Upgrade	20	\$0	\$0	\$0	\$0	0.0
			\$572,000	\$348,169	\$348,169	\$796,000	10.7

Fraction of Package Cost Covered by Energy Trust Incentive: 30%




100 hp Neuros Blowers




# Linear Motion Mixer Floating Cover Digester

Show Video!







ELEVATION VIEW



DETAIL B  
MIXER PORT COVER PLATE MOUNTING



DETAIL C  
SWITCH DETAIL



SECTION A-A  
DIGESTER PORT COVER PLATE

NOTES:

1. EIMCO WATER TECHNOLOGIES (EWT) WILL SUPPLY ONE (1) MOTION SLUDGE MIXER MECHANISM FOR MOUNTING ON A TANK. THE LM20 SLUDGE MIXER SHALL BE SUPPORTED FROM THE TANK AND SHALL BE CAPABLE OF MIXING SLUDGE WITHIN THE TANK.
2. EWT WILL SUPPLY ONE (1) ONE HYDRO-DISK PER LINEAR MIXER. A MINIMUM OF 96\"/>

REVISED PER RETURN SUBMITTAL (9/8/10) COMMENTS	S-001649	HCC	JAG	10/11/10	B	DATE	8/12/2010
INITIAL RELEASE					A	DRAWN	HCC

**EIMCO WATER TECHNOLOGIES**  
THIS DRAWING CONSTITUTES CONFIDENTIAL PROPRIETARY INFORMATION. IT IS TO BE USED ONLY FOR THE PROJECT AND FOR THE EQUIPMENT AND MATERIALS SPECIFICALLY IDENTIFIED THEREIN. IT IS NOT TO BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM.

ORIGINAL S.O.  
 CSW0000577-01

GEN  
LM20  
MD

# Linear Motion Mixer (Inside Digester)

HydroDisk Diameter 8 feet  
Travel (up and down) 20 inches  
30 cycles/minute



# Energy Efficiency By the Numbers

Project Cost	\$1,000,000 (estimated at \$600k)
Energy Trust Incentive	\$272,115
<u>BETC</u>	<u>\$220,000</u>
Capital Cost	\$507,885

## Energy Savings

Linear Motion Mixing 412,375

Neuros Blowers/Diffusers 437,983

850,358 kwh per year

\$58,270 per year

Approximate payback 8 years

# FOG Receiving Station



- 12,000 gallon receiving tank
- Tank Mixing Pump and FOG injection pump
- Projected 30 - 50% increase in gas production

# FOG Receiving Station Financing

- FOG Feasibility Study Completed with OECDD grant
- \$1,000,000 Phase 1 Construction under way
- \$40,000 Energy Trust Grant
- FOG Hauler RFP advertising this week
- Anticipated \$20,000 per month tipping fee revenue
- \$3,000,000 Phase 2 Cogeneration under design
- Anticipated 2-3 mil kwh per year additional production
- \$20,000 per month avoided utility costs
- Anticipated 7 year payback

# Energy Management Plan

- Keep it simple
- Select Energy Team Members (Ops, engineering, maintenance, etc)
- Meet Monthly for 1 hour and talk only energy
- Update Monthly energy production and consumption numbers every month
- Look and discuss trends
- Select and evaluate projects
- Stay on track!
- Assign projects to team members
- Keep Running agenda in EMP
- Update plan monthly (keep it alive!)



City of Gresham WWTP  
Energy Management Plan  
Updated January, 2012

**Brief Description of Utility and Scope (Fenceline):**

*Gresham WWTP physical fenceline and all WWTP facilities fed by main PGE utility meter.*

**Goals:** *Continue to increase renewable energy production as a % of energy used at site. These production and energy efficiency decisions need to have clear cost and payback analysis completed to justify project. In 2009, we averaged 7.2% renewable energy use on site. The goal is to become 100% energy independent within 5 year timeline. Construct digester mixing improvements and lower plant blower improvements in 2010/2011. Design FOG receiving facilities 2010, Construct 2011/12. Continue to try and get funding for Microhydro project. Design/Construct additional 400 kw cogeneration system with Cogen Phase 2 CIP by 2015/16. Complete Predesign FY 2012.*

**Targets:** *100% Energy independent by 2015/2016, 10% reduction in consumption by 2012/2013 with 2009 baseline. 12 month running average consumption of 450,000 kwh/month or less. Maximize cogen output and runtime at 390 kw average and 95% runtime.*

**Energy Management Team:**

*Alan Johnston, Paul proctor, Rich Ludlow, Jeff Maag*

**Energy Management Team Meetings (Meet Second Monday of each month):**

**Running Agenda:**

- Portfolio Manager Review of previous months kwh usage (Alan J)*
- E-manager review of data and improvements (Alan J)*
- Energy Management SOP status (Paul P)*
- Cogeneration Update (Rich L)*
  - H2S testing, Media Replacement History and next change out*
  - Oil Change Summary and Oil analysis results and trending*
  - Engine valve recession trending.*
- Cogenerator Life Cycle Costs (Alan J)*
- Top End or Major Overhaul Discussion. (Rich L)*
- Runtime Analysis and Veolia Runtime Incentive. (Paul P)*
- Operations and Control Issues (suggested improvements) (Group)*
- Capital Project Updates (Digester Mixing, Lower Turbo Blowers, Aeration Diffusers) (Jeff M)*



## Goal Reporting:

### Energy Summary

Benchmark from Portfolio Manager

## Energy Efficiency

### Electricity

Column	1	2	3	4	5	6
Time	Average kWh/month (1 Month)	Average kWh/year E-Manager	Average kWh/month (Column 2/ 12)	Total Flow: Million Gallons /year (influent)	Average kWh/million gallons (Column 2/ Column 4)	Portfolio Manager Score
<b>Goals</b>	<b>450,000</b>		<b>450,000</b>		<b>1,308</b>	<b>95</b>
1-12/2007	523,317	6,279,813	523,317	12.557 mgd, 4,583 Mg	1,468	
1-12/2008	489,643	5,875,720	489,643	11.808 mgd, 4,309 Mg	1,363	
1-12/2009- Baseline	483,599	5,803,190	483,049	11.492 mgd, 4,195 Mg	1,375	97
1-12/2010	485,273	5,823,282	485,273	12.491 mgd, 4,559 Mg	1,277	97
1-12/2011	488,554	5,128,775	427,398	12.127 mgd, 4,426 Mg	1,159	96
<b>% improvement</b>		None	None	8.7% increase	7.1%	0%
<b>Goal Met?</b>	<b>No</b>		<b>Yes</b>		<b>Yes</b>	<b>Yes</b>

2011 met goal

Lower plant Meter Installed 2/1/2011.

Column	1	2	3		4	5	6
Time	Lower Plant Average kWh/month (1 Month)	Lower Plant Average kWh/year	Lower Plant Average kWh/month (Column 2/ 12)	Lower Plant % kwh of entire Plant	Upper Plant Average kWh/month (1 Month)	Upper Plant Average kWh/year	Upper Plant Average kWh/month (Column 2/ 12)
1-12/2010	-	-	-	-	-	-	-
2-12/2011	291,324	3,181,029	289,184	67%		1,799,051	
<b>% improvement</b>		None	None			None	None

# Power Monitoring


- Monitor, store and evaluate power consumption
- PGE meter, lower plant, cogen, solar
- Data sent by cell to PGE E-manager website
- <http://www.portlandgeneral.com>, search “E-manager”
- About \$60/month per unit



# Energy Accomplishments Since 2005

- 18,000,000 Kwh produced by cogeneration
- 1,000,000 kwh produced by Solar
- 55% of WWTP power needs generated on site
- Over 26 billion gallons treated without a permit violation
- Approximately \$10,000,000 in Capital Projects built
- 6.2 mil kwh 2006, 5.4 mil kwh 2011
- 13% reduction in energy consumption
- 50% increase in energy production
- 76% of energy from sustainable sources
  - Cogeneration 50%
  - Solar 8% since 2010
  - Clean Wind program through PGE 18% since 2008
- Completed ACWA Sustainable Energy Training in 2011

# Energy Accomplishments Since 2005



# Next Steps

- |  |                   |
|--|-------------------|
| <b>1. Energy Management Team Meetings</b>    | <b>Monthly</b>    |
| <b>2. FOG Receiving Facilities, Complete</b> | <b>June, 2012</b> |
| <b>3. FOG Hauler Contract</b>                | <b>May, 2012</b>  |
| <b>4. Cogeneration expansion, Complete</b>   | <b>May 2014</b>   |
| <b>5. Evaluate Future Energy Projects</b>    | <b>Ongoing</b>    |
| <b>6. Energy Independent</b>                 | <b>2015 ?</b>     |



## Questions & Answers



Alan Johnston, Senior Engineer, Wastewater Services Division